



Product Service

CERTIFICATE

No. Z1 124139 0005 Rev. 00

Holder of Certificate: **SPA Corp Europe S.L.**
Poligono Industrial El Pintero C/Tejedores 22
41410 Carmona (Sevilla)
SPAIN

Certification Mark:



Product: **Scaffold**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: MES1477442541A00TR

Valid until: 2027-03-24

Date, 2024-01-17

(Andrea Rotundo)

CERTIFICATE

No. Z1 124139 0005 Rev. 00

Model(s): 14H0060; 14H0440; 14H0441.

Parameters:

Scaffold				
Code Model	Max dimensions [m] [LxWxH]	Max standing height [m]	Dead Load [kg]	Castor Type Ø [mm]
14H0060	2,12x1,9x3,91	2,75	93	125
14H0440	2,12x1,9x5,58	4,42	119	125
14H0441	2,17x2,1x7,23	6,06	162	125

Frame material: EN AW-6060 T6, EN AW-6063 T5

Rung material: EN AW-6060 T6, EN AW-6063 T5

Platform frame material: EN AW-6060 T6, EN AW-6063 T5

Platform material: EN 636 Class E80 F40 – Plywood (thickness=12 mm)

Group according to EN 1004-1:2020 = 3

Max.loading capacity = 2,0 kN/m²

Tested according to: PPP 52015C:2021
EN 1004-1:2020
EN 1004-2:2021